## ADVANCE

by (signify


Ballasts

Centium

ICN4P32N

## **Electrical Specifications at 120V**

Lamp Type	Num. of Lamps	Rated Lamp Watts	Min. Start Temp (۴/C)	Input Current (Amps)	Input Power (ANSI Watts)	Ballast Factor	MAX THD %	Power Factor	MAX Lamp Current Crest Factor	B.E.F.
* F17T8	3	17	0/-18	0.45	53	1.04	15	0.97	1.7	1.96
F17T8	4	17	0/-18	0.54	64	0.93	10	0.98	1.7	1.45
F25T8	3	25	0/-18	0.62	74	1.01	10	0.99	1.7	1.36
F25T8	4	25	0/-18	0.74	89	0.91	10	0.99	1.7	1.02
F32T8	3	32	0/-18	0.78	93	1.00	10	0.99	1.7	1.08
F32T8	4	32	0/-18	0.94	111	0.89	10	0.99	1.7	0.80
F32T8/ES (25W)	3	25	60/16	0.62	75	1.00	10	0.99	1.7	1.33
F32T8/ES (25W)	4	25	60/16	0.77	90	0.91	10	0.99	1.7	1.01
F32T8/ES (28W)	3	28	60/16	0.68	82	1.00	10	0.99	1.7	1.22
F32T8/ES (28W)	4	28	60/16	0.82	94	0.89	10	0.99	1.7	0.95
F32T8/ES (30W)	3	30	60/16	0.73	87	1.00	10	0.99	1.7	1.15
F32T8/ES (30W)	4	30	60/16	0.88	105	0.89	10	0.99	1.7	0.85
F40T8	3	40	32/00	0.94	112	0.97	10	0.99	1.7	0.87




Diag. 71

The wiring diagram that appears above is for the lamp type denoted by the asterisk  $(\sp{*})$ 

### Standard Lead Length (inches)

	in.	cm.		in.	cm.
Black	25	63.5	Yellow/Blue		0
White	25	63.5	Blue/White		0
Blue	31	78.7	Brown		0
Red	31	78.7	Orange		0
Yellow	39	99.1	Orange/Black		0
	39	99.1	Black/White		0
Gray		0	Red/White		0
Violet		0	1100/111110		Ŭ



### **Enclosure Dimensions**

[	OverAll (L)	Width (W)	Height (H)	Mounting (M)
	9.5 "	1.3 "	1.0 "	8.9 "
	9 1/2	1 3/10	1	8 9/10
	24.1 cm	3.3 cm	2.5 cm	22.6 cm



Revised 07/28/11

ICN-4P32-N@120V					
Brand Name	CENTIUM				
Ballast Type	Electronic				
Starting Method	Instant Start				
Lamp Connection	Parallel				
Input Voltage	120-277				
Input Frequency	50/60 HZ				
Status	Active				

### **Electrical Specifications**

#### Notes:

Section I - Physical Characteristics

1.1 Ballast shall be physically interchangeable with standard electromagnetic or standard electronic ballasts, where applicable.

1.2 Ballast shall be provided with integral leads color-coded per ANSI C82.11.

Section II - Performance

2.1 Ballast shall be \_\_\_\_\_ (Instant, Rapid or Programmed) Start.

2.2 Ballast shall provide Independent Lamp Operation (ILO) for Instant Start ballasts allowing remaining lamp(s) to maintain full light output when one or more lamps fail.

2.3 Ballast shall contain auto restart circuitry in order to restart lamps without resetting power (except T8/HO ballast).

2.4 Ballast shall operate from 50/60 Hz input source of \_\_\_\_\_\_ (120V through 277V or 347V through 480V) with sustained variations of +/- 10% (voltage and frequency).

2.5 Ballast shall be high frequency electronic type and operate lamps at a frequency above 42 kHz to avoid interference with infrared devices and eliminate visible flicker.

2.6 Ballast shall have a Power Factor greater than 0.98 for primary lamp.

2.7 Ballast shall have a minimum ballast factor for primary lamp application as follows: 0.75 for Low Watt, 0.85 for Normal Light Output and 1.20 for High Light.

2.8 Ballast shall provide for a Lamp Current Crest Factor of 1.7 or less.

2.9 Ballast input current shall have Total Harmonic Distortion (THD) of less than 10% when operated at nominal line voltage with primary lamp. 2.10 Ballast shall have a Class A sound rating for all 4-foot lamps and smaller.

2.11 Ballast shall have a minimum starting temperature of \_\_\_\_\_ [-18C (0F) for standard T8 and Long Twin Tube lamps, 10C (50F) for standard T12 lamps, 0C (32F) for Slimline T8 lamps, -29C (-20F) for HO lamps,] for primary lamp application. Ballast shall have a minimum starting temperature of 16C (60F) for energy-saving lamps.

2.12 Ballast shall tolerate sustained open circuit and short circuit output conditions.

2.13 Ballast for T8 lamps shall provide lamp striation-reduction circuitry.

2.14 Ballast for FT5 lamps shall provide lamp EOL protection circuitry.

Section III - Regulatory

3.1 Ballast shall not contain any Polychlorinated Biphenyl (PCB).

3.2 Ballast shall be Underwriters Laboratories (UL) listed, Class P and Type 1 Outdoor; and Canadian Standards Association (CSA) certified where applicable.

3.3 Ballast shall comply with ANSI C62.41 Category A for Transient protection.

3.4 Ballast shall comply with ANSI C82.11 where applicable.

3.5 Ballast shall comply with applicable requirements of the Federal Communications Commission (FCC) rules and regulations, Title 47 CFR part 18, for Non-Consumer equipment.

3.6 Ballast shall comply with NEMA 410 for in-rush current limits.

3.7 Ballast for T8 lamps shall meet NEMA Premium/CEE High Performance T8 Lighting System Specifications.

3.8 Ballast shall meet RoHS Compliance Standards

Section IV - Other

4.1 Ballast shall be manufactured in a factory certified to ISO 9001 Quality System Standards.

4.2 Ballast shall carry a five-year warranty from date of manufacture against defects in material or workmanship, including replacement, for operation at a maximum case temperature of 70C.

4.3 Manufacturer shall have a twenty-year history of producing electronic ballasts for the North American market.

4.4 Energy saving T8 lamps (25W, 28W or 30W) may experience lamp striations if operated on ballasts not rated for their use.




Revised 07/28/11

### **Electrical Specifications at 277V**

Lamp Type	Num. of Lamps	Rated Lamp Watts	Min. Start Temp (℉/C)	Input Current (Amps)	Input Power (ANSI Watts)	Ballast Factor	MAX THD %	Power Factor	MAX Lamp Current Crest Factor	B.E.F.
* F17T8	3	17	0/-18	0.20	53	1.04	15	0.97	1.7	1.96
F17T8	4	17	0/-18	0.23	64	0.93	10	0.98	1.7	1.45
F25T8	3	25	0/-18	0.27	74	1.01	10	0.99	1.7	1.36
F25T8	4	25	0/-18	0.32	89	0.91	10	0.99	1.7	1.02
F32T8	3	32	0/-18	0.33	93	1.00	10	0.99	1.7	1.08
F32T8	4	32	0/-18	0.41	111	0.89	10	0.99	1.7	0.80
F32T8/ES (25W)	3	25	60/16	0.27	73	1.00	10	0.98	1.7	1.37
F32T8/ES (25W)	4	25	60/16	0.33	87	0.89	10	0.98	1.7	1.02
F32T8/ES (28W)	3	28	60/16	0.68	80	1.00	10	0.99	1.7	1.25
F32T8/ES (28W)	4	28	60/16	0.36	91	0.89	10	0.99	1.7	0.98
F32T8/ES (30W)	3	30	60/16	0.32	87	1.00	10	0.99	1.7	1.15
F32T8/ES (30W)	4	30	60/16	0.38	105	0.89	10	0.99	1.7	0.85
F40T8	3	40	32/00	0.40	112	0.97	10	0.99	1.7	0.87








Insulate unused blue lead for 1000V

The wiring diagram that appears above is for the lamp type denoted by the asterisk (\*)

### Standard Lead Length (inches)

	in.	cm.		in.	cm.
Black	25	63.5	Yellow/	Blue	0
White	25	63.5	Blue/W	'hite	0
Blue	31	78.7	Br	own	0
Red	-	94	Ora	inge	0
	37	-	Orange/B	0	0
Yellow	39	99.1	Black/W		0
Gray		0	Red/W		0
Violet		0	Tteu/W		0



### **Enclosure Dimensions**

OverAll (L)	Width (W)	Height (H)	Mounting (M)
9.5 "	1.3 "	1.0 "	8.9 "
9 1/2	1 3/10	1	8 9/10
24.1 cm	3.3 cm	2.5 cm	22.6 cm



ICN-4P32-N@277V					
Brand Name	CENTIUM				
Ballast Type	Electronic				
Starting Method	Instant Start				
Lamp Connection	Parallel				
Input Voltage	120-277				
Input Frequency	50/60 HZ				
Status	Active				

### **Electrical Specifications**

#### Notes:

Section I - Physical Characteristics

1.1 Ballast shall be physically interchangeable with standard electromagnetic or standard electronic ballasts, where applicable.

1.2 Ballast shall be provided with integral leads color-coded per ANSI C82.11.

Section II - Performance

2.1 Ballast shall be \_\_\_\_\_ (Instant, Rapid or Programmed) Start.

2.2 Ballast shall provide Independent Lamp Operation (ILO) for Instant Start ballasts allowing remaining lamp(s) to maintain full light output when one or more lamps fail.

2.3 Ballast shall contain auto restart circuitry in order to restart lamps without resetting power (except T8/HO ballast).

2.4 Ballast shall operate from 50/60 Hz input source of \_\_\_\_\_\_ (120V through 277V or 347V through 480V) with sustained variations of +/- 10% (voltage and frequency).

2.5 Ballast shall be high frequency electronic type and operate lamps at a frequency above 42 kHz to avoid interference with infrared devices and eliminate visible flicker.

2.6 Ballast shall have a Power Factor greater than 0.98 for primary lamp.

2.7 Ballast shall have a minimum ballast factor for primary lamp application as follows: 0.75 for Low Watt, 0.85 for Normal Light Output and 1.20 for High Light.

2.8 Ballast shall provide for a Lamp Current Crest Factor of 1.7 or less.

2.9 Ballast input current shall have Total Harmonic Distortion (THD) of less than 10% when operated at nominal line voltage with primary lamp. 2.10 Ballast shall have a Class A sound rating for all 4-foot lamps and smaller.

2.11 Ballast shall have a minimum starting temperature of \_\_\_\_\_ [-18C (0F) for standard T8 and Long Twin Tube lamps, 10C (50F) for standard T12 lamps, 0C (32F) for Slimline T8 lamps, -29C (-20F) for HO lamps,] for primary lamp application. Ballast shall have a minimum starting temperature of 16C (60F) for energy-saving lamps.

2.12 Ballast shall tolerate sustained open circuit and short circuit output conditions.

2.13 Ballast for T8 lamps shall provide lamp striation-reduction circuitry.

2.14 Ballast for FT5 lamps shall provide lamp EOL protection circuitry.

Section III - Regulatory

3.1 Ballast shall not contain any Polychlorinated Biphenyl (PCB).

3.2 Ballast shall be Underwriters Laboratories (UL) listed, Class P and Type 1 Outdoor; and Canadian Standards Association (CSA) certified where applicable.

3.3 Ballast shall comply with ANSI C62.41 Category A for Transient protection.

3.4 Ballast shall comply with ANSI C82.11 where applicable.

3.5 Ballast shall comply with applicable requirements of the Federal Communications Commission (FCC) rules and regulations, Title 47 CFR part 18, for Non-Consumer equipment.

3.6 Ballast shall comply with NEMA 410 for in-rush current limits.

3.7 Ballast for T8 lamps shall meet NEMA Premium/CEE High Performance T8 Lighting System Specifications.

3.8 Ballast shall meet RoHS Compliance Standards

Section IV - Other

4.1 Ballast shall be manufactured in a factory certified to ISO 9001 Quality System Standards.

4.2 Ballast shall carry a five-year warranty from date of manufacture against defects in material or workmanship, including replacement, for operation at a maximum case temperature of 70C.

4.3 Manufacturer shall have a twenty-year history of producing electronic ballasts for the North American market.

4.4 Energy saving T8 lamps (25W, 28W or 30W) may experience lamp striations if operated on ballasts not rated for their use.



Revised 07/28/11

The information presented in this document is not intended as any commercial offer and does not form part of any quotation or contract.

# Signify

2019 Signify Holding. All rights reserved. This document contains information relating to the product portfolio of Signify which information may be subject to change. No representation or warranty as to the accuracy or completeness of the information included herein is given and any liability for any action in reliance thereon is disclaimed. All trademarks are owned by Signify Holding or their respective owners. Signity North America Corporatio 200 Franklin Square Drive, Somerset, NJ 08873 Telephone 855-486-2216 Signify Canada Ltd. 281 Hillmount Road, Markham, ON, Canada L6C 2S3 Telephone 800-668-9008